

# NIGHT INCIDENT



## Report

Site

Barcelona

Date and time

2023-10-16 01:30

Attended

Phone

Site

Department

Engineering

Scope

Yes

No

System

Cyclotron - WCS

System description

Describe the incident

Water problems detected.

Solved?

Yes

No

Derived?

Yes

No

To whom?

Yes - Site manager

Yes - Production manager

Yes - QA

Yes - QC

Yes - QP

Others

Who is other?

Production affected?

No

Yes - Totally cancelled

Yes - Partially cancelled

Yes - Delayed

Any comment?

No

If possible, describe the solution

Water cooling system pump drain and lower the conductivity of water

If possible, describe the root cause

TotalTimeOfIntervention

1.0