

NIGHT INCIDENT

Report



Site

Murcia

Date and time

2023-11-10 06:00

Attended

Phone

Site

Department

Engineering

Scope

Yes

No

System

Others - Electrical power

System description

Describe the incident

UPS distribution breaker down

Solved?

Yes

No

Derived?

Yes

No

To whom?

Yes - Site manager

Yes - Production manager

Yes - QA

Yes - QC

Yes - QP

Others

Who is other?

Production affected?

No

Yes - Totally cancelled

Yes - Partially cancelled

Yes - Delayed

Any comment?

If possible, describe the solution

It seems there is a short circuit in a computer

If possible, describe the root cause

TotalTimeOfIntervention

10.0