

NIGHT INCIDENT



Report

Site

Barcelona

Date and time

2024-05-13 00:03

Attended

Phone

Site

Department

Engineering

Scope

Yes

No

System

System description

Describe the incident

The door of the Petrace cannot open.

Solved?

Yes

No

Derived?

Yes

No

To whom?

Yes - Site manager

Yes - Production manager

Yes - QA

Yes - QC

Yes - QP

Others

Who is other?

Production affected?

No

Yes - Totally cancelled

Yes - Partially cancelled

Yes - Delayed

Any comment?

If possible, describe the solution

I show the left sensor wasn't working. I adjusted the sensor and the problem was solve.

If possible, describe the root cause

The foam was covering the sensor (?) (I am not sure)

TotalTimeOfIntervention

60.0