

NIGHT INCIDENT



Report

Site

Oporto

Date and time

2023-05-01 23:45

Attended

Phone Site

Department

Engineering

Scope

Yes No

System

System description

Describe the incident

Chiller failure - vacuum lost

Solved?

Yes No

Derived?

Yes No

To whom?

Yes - Site manager Yes - Production manager Yes - QA Yes - QC Yes - QP Others

Who is other?

Production affected?

No Yes - Totally cancelled Yes - Partially cancelled Yes - Delayed

Any comment?

If possible, describe the solution

To change to the other chiller and restart the vacuum.

If possible, describe the root cause

Chiller problem

TotalTimeOfIntervention

165.0