

NIGHT INCIDENT



Report

Site

Meldola

Date and time

2023-12-03 22:15

Attended

Phone

Site

Department

Production,E&S

Scope

Yes

No

System

System description

Describe the incident

LAF-02 can't start up. Seems some electrical components on failure

Solved?

Yes

No

Derived?

Yes

No

To whom?

Yes - Site manager

Yes - Production manager

Yes - QA

Yes - QC

Yes - QP

Others

Who is other?

Production affected?

No

Yes - Totally cancelled

Yes - Partially cancelled

Yes - Delayed

Any comment?

If possible, describe the solution

Replaced mother board, LAF-02 can run again but not in normal mode

If possible, describe the root cause

Probably the electrical maintenance performed on Saturday 02/12/2023

TotalTimeOfIntervention

195.0