

NIGHT INCIDENT



Report

Site

Venafro

Date and time

2023-12-18 05:50

Attended

Phone Site

Department

Production

Scope

Yes No

System

System description

Describe the incident

Pump disconnected at the start distribution of batch C

Solved?

Yes No

Derived?

Yes No

To whom?

Yes - Site manager Yes - Production manager Yes - QA Yes - QC Yes - QP Others

Who is other?

Production affected?

No Yes - Totally cancelled Yes - Partially cancelled Yes - Delayed

Any comment?

If possible, describe the solution

Restart PC

If possible, describe the root cause

Operator didn't log off his account at the end of batch B

TotalTimeOfIntervention

5.0