

NIGHT INCIDENT



Report

Site

Venafro

Date and time

2024-01-18 01:42

Attended

Phone Site

Department

Production,E&S

Scope

Yes No

System

System description

Describe the incident

Cooling water system fault

Solved?

Yes No

Derived?

Yes No

To whom?

Yes - Site manager Yes - Production manager Yes - QA Yes - QC Yes - QP Others

Who is other?

Production affected?

No Yes - Totally cancelled Yes - Partially cancelled Yes - Delayed

Any comment?

If possible, describe the solution

Restart chiller, SW and wait for DP ok

If possible, describe the root cause

Shut down of chiller- no water flow in Swedewater

TotalTimeOfIntervention

15.0