

# NIGHT INCIDENT

## Report



Site

Meldola

Date and time

2024-04-12 11:57

Attended

Phone  Site

Department

E&S,Production

Scope

Yes  No

System

System description

Describe the incident

Condizionatori non funzionanti cq accesso ciclo e sala server

Solved?

Yes  No

Derived?

Yes  No

To whom?

Yes - Site manager  Yes - Production manager  Yes - QA  Yes - QC  Yes - QP  Others

Who is other?

Production affected?

No  Yes - Totally cancelled  Yes - Partially cancelled  Yes - Delayed

Any comment?

If possible, describe the solution

Corto circuito nel AC cq room

If possible, describe the root cause

TotalTimeOfIntervention

20.0