

# NIGHT INCIDENT



## Report

Site

Meldola

Date and time

2024-06-01 01:36

Attended

Phone  Site

Department

Production

Scope

Yes  No

System

System description

Describe the incident

Il robot di disperazione non risponde agli input

Solved?

Yes  No

Derived?

Yes  No

To whom?

Yes - Site manager  Yes - Production manager  Yes - QA  Yes - QC  Yes - QP  Others

Who is other?

Production affected?

No  Yes - Totally cancelled  Yes - Partially cancelled  Yes - Delayed

Any comment?

If possible, describe the solution

Riconnesso il cavo scart di comunicazione

If possible, describe the root cause

Probabilmente durante l'intervento di Comecer è stato tirato il cavo di comunicazione che si è disconnesso

TotalTimeOfIntervention

15.0