

# NIGHT INCIDENT



## Report

Site

Venafro

Date and time

2024-06-26 04:35

Attended

Phone  Site

Department

E&S,Production

Scope

Yes  No

System

System description

Describe the incident

HVV closed due to a fault in cooling system

Solved?

Yes  No

Derived?

Yes  No

To whom?

Yes - Site manager  Yes - Production manager  Yes - QA  Yes - QC  Yes - QP  Others

Who is other?

Production affected?

No  Yes - Totally cancelled  Yes - Partially cancelled  Yes - Delayed

Any comment?

If possible, describe the solution

Restart chiller

If possible, describe the root cause

Error in chiller compressor

TotalTimeOfIntervention

10.0